

GB Network Access Policy

Key Performance Indicators 2023/24

July 2024

Document Classification | Public



Τ R A N S M I S S I O N



Overview

As part of SSEN Transmission's commitment to ensure we have fully transparent outage planning processes, we produce a series of annual key performance indicators (KPIs) to monitor our outage planning performance and outage delivery. The KPI's have been developed following feedback from consumers and stakeholders across GB.

The KPIs are part of our obligations under the GB Network Access Policy. The Policy is designed to facilitate collaboration between the GB Transmission Owners and National Grid Electricity System Operator (NGESO) to deliver value for consumers in relation to planning, management and operation of the GB transmission network. The KPIs are described in Appendix A of the GB Network Access Policy, and can be found <u>here</u> on our website.

The SSEN Transmission KPIs for 2023/24 are provided in the next section.



Network Access Policy KPIs 2023/24

Term Outage Planning Performance are of the number of outages in the year at a contract of actual outages delivered in the 2023				
are of the number of outages in the year are of actual outages delivered in the 2023				
Measure of the number of outages in the year ahead plan submitted at week 49 (Dec 2022) vs the number of actual outages delivered in the 2023/24 regulatory year (01 Apr 2023 and 31 Mar 2024). This is a high-level measure of Long-Term Outage Planning Performance				
Number of outages in the year ahead plan	524	513 'out-of-service' outages, and 11 'in- service' outages.		
Number of these outages delivered	338	329 'out-of-service' outages, and 9 'in- service' outages.		
Percentage of year ahead plan delivered	64.5%			
acy of the Year Ahead Outage Plan				
This is a measure of the TO's capability to construct and deliver a robust outage plan. This is detailed measure of Long-Term Outage Planning Performance				
Percentage of outages started on the date agreed at the year ahead stage – week 49 (Dec 2022)	31.9%	Includes 'out-of-service' and 'in-service' outage bookings.		
Percentage of outages started within the outage week agreed at the year ahead stage – week 49 (Dec 2022)	40.1%	Includes 'out-of-service' and 'in-service' outage bookings.		
Percentage of outages changed in the year ahead plan for a "positive" reason.	8.2%	Includes; outage bundling, request to accelerate works, early completion of works, and User or ESO requests to change an outage.		
Year Outage Planning Performance				
Measure of new outages requested within year by the TO during the relevant regulatory year. These are essential outages to carry out defect repairs, remove potential hazards or complete construction works. There is a balance of flexibility and these measures are intended to show a reduction in the number of short-term requests being made.				
Number of new within year (2023/24) outages submitted to NGESO prior to the Optimisation phase (17 - 52 weeks ahead)	88			
Number of new within year (2023/24) outages submitted to NGESO during the Optimisation Phase (4 – 16 weeks ahead as specified in STCP 11.1)	212			
Number of new within year (2023/24) outages submitted to NGESO during the delivery Phase (0 – 3 weeks	522			
	Percentage of outages started on the date agreed at the year ahead stage – week 49 (Dec 2022) Percentage of outages started within the outage week agreed at the year ahead stage – week 49 (Dec 2022) Percentage of outages changed in the year ahead plan for a "positive" reason. Year Outage Planning Performance re of new outages requested within year ential outages to carry out defect repair There is a balance of flexibility and thes r of short-term requests being made. Number of new within year (2023/24) outages submitted to NGESO prior to the Optimisation phase (17 - 52 weeks ahead) Number of new within year (2023/24) outages submitted to NGESO during the Optimisation Phase (4 – 16 weeks ahead as specified in STCP 11.1) Number of new within year (2023/24) outages submitted to NGESO during the delivery Phase (0 – 3 weeks ahead as specified in STCP 11.1)	Percentage of outages started on the date agreed at the year ahead stage – week 49 (Dec 2022)31.9%Percentage of outages started within the outage week agreed at the year ahead stage – week 49 (Dec 2022)40.1%Percentage of outages changed in the year ahead plan for a "positive" reason.8.2%Year Outage Planning Performance re of new outages requested within year by the TO du tential outages to carry out defect repairs, remove pote There is a balance of flexibility and these measures a r of short-term requests being made.88Number of new within year (2023/24) outages submitted to NGESO prior to the Optimisation phase (17 - 52 weeks ahead)88Number of new within year (2023/24) outages submitted to NGESO during the Optimisation Phase (4 - 16 weeks ahead as specified in STCP 11.1)212Number of new within year (2023/24) outages submitted to NGESO during the Optimisation Phase (0 - 3 weeks ahead as apecified in STCP 11.1)522		



	DESCRIPTION	MEASURE	COMMENTS	
4	How Many Connection Assets or Transmission Circuits Are Out of Service More Than Once Per Annum?			
	Measure of the number of times the same item of equipment or circuit is removed from service.	348	Out of service outages only. The total volume was primarily as a consequence of major infrastructure and connection works requiring local circuits on outage on multiple occasions to facilitate construction and commissioning activities.	
5	Outage Coordination			
	Measure of the number of times the TO has carried out different work during a single outage. Measure is based on the number of outages that have been combined into a single outage vs the total number of outages delivered in the regulatory year.	150	Out of service outages only. This covers alignment of construction, substation maintenance, and overhead line inspection activities where it was practical to do so in order to minimise outage impact to the ESO and to contracted Users.	
6	Percentage of TO Outages Started Within 60mins of Agreed Start Time			
	Measure of outage start time accuracy will be the agreed Planned Start Time compared to the Actual Start Time.	67.3%	This amounts to 770 outages of the 1144 actual outages completed, which started within 60 mins of the agreed start times. The agreed start times include times re-scheduled up to the day before the actual outage start.	
	Transmission Connected Generation			
7	Percentage of Annual Access Curtailed by Bila Connections	teral Connecti	on Agreement Per Annum - Firm	
	Measure of lost network access due to transmission outages and connection agreements. Measure would be 100 x (total days of actual outages \ 365).	0		
	ransmission Connected Generation			
8	Percentage of Annual Access Curtailed by Bilateral Connection Agreement Per Annum – Non-Fi Connections			
	Measure of lost network access due to transmission outages and connection agreements. Measure would be 100 x (total days of actual outages \ 365).	3.3%	40 generators were curtailed at some point in 2023/24, of the 47 transmission- connected generators in the SSEN Transmission area. This curtailment averaged across the 40 affected generators at 3.3% (12 days), varying between 46.8% for the worst affected generator, down to 0.1% for the least affected generator.	



	DESCRIPTION		MEASURE	COMMENTS	
	Average Outage Duration Accuracy				
9	Measure of TO ability to plan outage durations.				
	9.a	Average outage duration accuracy – year ahead outage plan (week 49 - Dec 2022) % of outages finished early % of outages finished late % of outages finished on time	33.2% 23.7% 43.1%	Includes 'out-of-service' and 'in-service' outage bookings, and only the 338 planned outages (KPI 1b) included in the week 49 (Dec 2022) baseline plan that were delivered in the 2023/24 regulatory year between 01 Apr 2023 and 31 Mar 2024.	
	9.b	Average outage duration accuracy - within year outages (01 Apr 2023 and 31 Mar 2024) % of outages finished early % of outages finished late % of outages finished on time	12.1% 4.1% 83.8%	Includes 'out-of-service' and 'in-service' outage bookings, and covers 806 of new additional outages not included in the week 49 (Dec 2022) baseline Outage Plan, and delivered in the 2023/24 regulatory year between 01 Apr 2023 and 31 Mar 2024.	
	Numb	or of Upplanned Outages Due to Fau	ts or Defects		
10	This is a measure of the number of times an asset or circuit has been removed from service due to a system fault, has been removed from service by emergency switching or has been made unavailable to NGESO and removed from service.				
	10.a.	Number of system faults removing an asset or circuit from service	97	Caused by operation of a protection system in response to component failures or external causes and including circuit auto-reclosures.	
	10.b.	Number of emergency switching outages removing an asset or circuit from service	0		
	10.c.	All other unplanned outages when an asset or circuit has been made unavailable to NGESO due to a defect	45	Unplanned outages within operational timescales as a result of recognising a condition that is expected to develop into a fault. Includes; switchgear gas top-ups, and defect repairs on lines, cables, and substation plant/ equipment.	



	DESC	CRIPTION	MEASURE	COMMENTS	
11	Enhanced Service Provision Measure of the number of STCP11.4 proposals identified within a regulatory year.				
	11.a.	Number of proposals identified by NGESO or TO	2		
	11.b.	Number of proposals delivered by the TO			
	11.c.	Measure of System Operational costs savings vs cost to deliver by TO	£59.62 M	Although no new proposals were delivered in 2023/24, the two existing schemes provided the net cost saving of £59.62 M.	
12	In Ser	vice Works			
		Measure of the number of "In Service" bookings to highlight works taking place without an asset being taken out of service.	144	Includes; OHL delayed auto-reclose (DAR) outages, circuit risk of trips, telecoms outages, and equipment/circuit testing outages	



Contact

For any queries, please get in touch at

SSEN Transmission Control Centre Grampian House 200 Dunkeld Road Perth PH1 3GH currentyear.transmission.outages@sse.com