



- #### GENERAL NOTES
- CONSTRUCTION PERFORMED IN ACCORDANCE TO THE SPECIFICATION AND RELEVANT STANDARDS.
 - ALL COMPONENTS OF THE PALISADE TO BE GALVANIZED TO BS 5739.
 - WIRE BRUSHED & WARE COAT WITH APPROVED ZINC RICH PAINT.
 - PALISADE PANELS SHALL BE ATTACHED TO INTERMEDIATE AND END POSTS BY PERMANENTLY GALVANIZED SHEAR NUTS AND WASHERS.
 - CONCRETE SHALL BE SUPPLIED BY AN APPROVED SUPPLIER AND SHALL BE CAST AND CURED IN ACCORDANCE WITH BS 5155.
 - MAXIMUM PERMISSIBLE SPACE BETWEEN ADJACENT PANELS SHALL BE 146mm.
 - CONCRETE SHALL BE CAST AND CURED IN ACCORDANCE WITH BS 5155.
 - ALL KEYS TO BE 50mm LENGTH IN ACCORDANCE WITH BS 5155.
 - FOR PROTECTION, THE PALISADE SHALL BE PRODUCED TO THIS SPECIFICATION WITH A MINIMUM OF 10% GALVANIZATION.
 - MINIMUM THICKNESS BEFORE GALVANIZING 2.8mm.
 - FIXING TO BE M8 T-HEADED BOLTS WITH PERMANENT SHEAR NUTS.
 - PROFILE OF APPROVED PALE.

NOTES-

NOT TO SCALE

UNCONTROLLED COPY		
SUBJECT TO REVISION	MATERIALIZED	REVISION HEAD
TELEPHONE \$33\$33\$33\$33	TELEPHONE \$33\$33\$33\$33	TELEPHONE \$33\$33\$33\$33

This drawing is protected by copyright and the information contained therein is confidential. It is the property of Scottish and Southern Energy plc and shall remain the property of Scottish and Southern Energy plc. It is not to be copied, reproduced or disclosed to a third party, wholly or in part, without the written permission of, and in the name of, Scottish and Southern Energy plc. © 2015

Scale:-	AS SHOWN	Dimensions in millimetres
Dwn. by:-	LW/MKL (3/D)	
Tcd. by:-	T. DOWLING	
Ckd. by:-	T. DOWLING	
App. by:-		
Drawing no. CE/34/2015		
C.A.D. Reference:- Palifentis.dgn		
DATE PLOTTED	\$33\$33\$33\$33	