

## **TECHNICAL APPENDIX 14.3: SOURCE NOISE LEVELS**

### **1. APPENDIX 14.3 SOURCE NOISE LEVELS**

1-2

## 1. APPENDIX 14.3 SOURCE NOISE LEVELS

**Table 1-1: Equipment Sound Power Levels**

Equipment	Quantity	Housing Arrangements	Sound Power Level (SWL) (dB(A))
Transformers	3	External	86
Transformer Cooling	3	External	85
Synchronous Compensator	4	Internal	92
Synchronous Compensators (Step up Transformer)	4	External	83
Synchronous Compensators (Start up Transformer)	4	External	83
Synchronous Compensators (Auxiliary Transformer)	4	External	84
Synchronous Compensator Coolers	4	External	95
Reactor	3	External	85
Reactor Cooling	3	External	84

**Table 1-2: Sound Reduction – Building Facades - 200mm Rockspan and Firemaster Ultima**

**Sound Insulation Prediction (v7.0.13)**

Program copyright Marshall Day Acoustics 2012

- Key No. 2517

Margin of error is generally within  $R_w \pm 3$  dB

Job Name:

Job No.:


Page No.:

Notes:

Date: 30 Apr 20

Initials: tim ashley

File Name: insul



$R_w$  36 dB  
C -3 dB  
 $C_{tr}$  -5 dB

**System description**

Panel 1 Outer layer: 1 x 200.0 mm Rockspan Ultima 200mm- ( $m=37.7$  kg/m<sup>2</sup>,  $f_c=119690$  Hz, Damping=0.01) Profile

frequency (Hz)	R(dB)	R(dB)
50	22	
63	23	23
80	25	
100	26	
125	27	27
160	29	
200	30	
250	31	31
315	32	
400	33	
500	33	32
630	30	
800	24	
1000	36	28
1250	44	
1600	46	
2000	48	48
2500	49	
3150	51	
4000	53	53
5000	55	

